

RECALL NOTICE

ITW Canada recalls Red Head Trubolt+ wedge anchors



HAZARD: The affected product does not meet the requirements for use in cracked concrete and seismic applications, which may lead to incidents or injuries to consumers.

RECALLED PRODUCT: Red Head Trubolt+ wedge anchors used for concrete anchoring in the following sizes: 1/2, 1/4, 3/4, 3/8, 5/8 sold from March 2017 to April 2018

REMEDY: Consumers should immediately stop using the recalled product and return it to the retailer for a full refund.

FOR MORE INFORMATION: see www.tbplusinfo.com or call 1-800- 387- 6427 Monday to Friday 9:00AM-5:00PM EST.