


# SAFETY NOTICE

KN-COSM-IBACA (900-0119)

i12010S-CA

i12010S-CO-CA



**Name of Product:** Kidde AC/DC Powered Residential Smoke Alarms and Combination Smoke/CO Alarm models: KN-COSM-IBACA (900-0119)—manufactured 11/19/13 - 5/13/14. Feature on this alarm will be a front load battery door and 2 AA batteries. Models with a rear load battery door and 9V battery are not part of this recall. i12010S-CO-CA—Combination Smoke/Carbon Monoxide Alarm--manufactured 3/14/14 – 5/13/14 and 6/6/14; and i12010S-CA Smoke Alarm – manufactured 3/11/14 - 5/13/14.

These units are AC/DC powered and capable of hardwired interconnect. They have a Kidde logo on the face of the unit. The model number is on the label on the back of the unit.

**Identified Hazard:** If a power outage occurs at the same second that a unit is performing a sensor health check, the units may go into a “latched” mode, causing them not to alert to the presence of smoke. It will sound if it receives a signal from an alarm in the same interconnected system. Once power is restored, a latched unit will sound an alert, regardless of the presence of smoke or carbon monoxide, until power to the alarm is completely removed.

**Remedy:** Replace unit. Consumers should not take the alarm out of service until they receive a replacement from Kidde Canada.

**Kidde Product Support:** Call Kidde Canada’s Recall Center at 1-888-784-2323 between 8:00 a.m. – 5:00 p.m. EST Monday through Friday, except holidays, or visit our website at [www.kiddecanada.com](http://www.kiddecanada.com). Calls consumers may have of a technical nature that are not related to the recall should be transferred to our toll-free number.

Post until December 1, 2015

In cooperation with Health Canada